



TYPE "B"

NOTES:

- 1. TAP FOR AIR RELEASE VALVE SHALL BE STANDARD THREADED TAP OR SADDLE TAP DEPENDING ON MANUFACTURER'S RECOMMENDATION FOR TYPE AND THICKNESS OF PIPE ENCOUNTERED.
- 2. GRAVEL BEDDED MAY BE USED IN PLACE OF CONCRETE IN NON-TRAFFIC AREAS AT DESCRETION OF ENGINEER.
- 3. PIPE SHALL BE BLACK IRON / GALVANIZED PIPE.
- 4. IF 4" OR 6" PVC PIPE IS USED, SADDLE IS REQUIRED FOR CORPORATION STOP.
- 5. ALL COPPER FITTINGS WILL BE FLARE TYPE.

AR RELEASE VALVE AND BOX WATER AND SANITARY SEWER FACILITIES

VIRGINIA DEPARTMENT OF TRANSPORTATION