

SURVEYED BY _____
SUPERVISED BY _____
DESIGNED BY _____

DESIGN FEATURES RELATING TO CONSTRUCTION OR TO REGULATION AND CONTROL OF TRAFFIC MAY BE SUBJECT TO CHANGE AS DEEMED NECESSARY BY THE DEPARTMENT

REVISED	STATE	FEDERAL AID		STATE		SHEET NO.
		PROJECT	ROUTE	PROJECT		
	VA.					

NOTES

- DEPTH OF INLET (H) TO BE SHOWN ON PLANS FOR DEPTH GREATER THAN 10' USE STANDARD DI-1A
- THE 1/4" DIMENSION SHOWN ON THE PLANS STANDARDS AND SPECIFIED ON THE INVERT OF THE STRUCTURE. PLAN "H" DIMENSIONS ARE APPROXIMATE ONLY. FOR ESTIMATING PURPOSES ONLY. THE ACTUAL DIMENSIONS SHALL BE DETERMINED BY THE CONTRACTOR FROM FIELD CONDITIONS.
- WHEN SPECIFIED ON THE PLANS THE INVERT OF THE STRUCTURE SHALL BE SHAPED IN ACCORDANCE WITH STANDARD ST-1. THE COST OF MATERIALS FURNISHING AND PLACING ALL MATERIALS INCIDENTAL TO THE SHAPING IS TO BE INCLUDED IN THE BID PRICE FOR THE STRUCTURE.
- IN THE EVENT THE INVERT OF THE OUTFALL PIPE IS HIGHER THAN THE BOTTOM OF THE STRUCTURE, THE INVERT OF THE STRUCTURE SHALL BE SHAPED WITH CEMENT MORTAR TO PREVENT THE STRUCTURE FROM BEING FURNISHED AND PLACING ALL MATERIALS INCIDENTAL TO INLET SHAPING IS TO BE INCLUDED IN THE BID PRICE FOR THE STRUCTURE.
- STEPS ARE TO BE PROVIDED WHEN H IS 4'-0" OR GREATER. FOR DETAILS SEE STANDARD ST-1.
- THIS ITEM MAY BE PRECAST OR CAST-IN-PLACE.
- # 4 X 8" SMOOTH DOWELS AT APPROXIMATELY 12" C-C TO BE PLACED IN ALL AREAS ADJACENT TO CASTING CONCRETE TO PREVENT CRACKING. A 2"x4" NOTCH MAY BE PROVIDED. SEE STANDARD T-DI-3, 4 FOR ALTERNATE DESIGN.
- 3" DIAMETER WEEP HOLE WITH 1/4"x12" PLASTIC HARDWARE CLOTH 1/4" MESH OR GALVANIZED STEEL WIRE MINIMUM WIRE DIAMETER 0.03". NUMBER 4 MESH HARDWARE CLOTH ANCHORED FIRMLY TO THE OUTSIDE OF THE STRUCTURE.
- CAST IN PLACE CONCRETE IS TO BE CLASS A3 (3000 PSI). PRECAST CONCRETE IS TO BE 4000 PSI.
- ANY ALTERNATE METHODS OF ANCHORAGE SILENTLY APPROVED BY THE ENGINEER MAY BE SUBSTITUTED FOR THE CAST IRON LUGS AS SHOWN HEREON.
- DUMP NO. WASTE DRAINS TO WATERWAY CAST IRON COLLAR. LETTERING MAY VARY BY MANUFACTURER.

CONCRETE QUANTITIES FOR MIN. DEPTH

12" CONCRETE PIPE - 1,440 CU. YD. CONCRETE
15" CONCRETE PIPE - 1,528 CU. YD. CONCRETE
18" CONCRETE PIPE - 1,620 CU. YD. CONCRETE
24" CONCRETE PIPE - 1,817 CU. YD. CONCRETE
ADD 0.468 CU. YD. PER ADDITIONAL FOOT OF DEPTH.

STANDARD DROP INLET
12" - 24" PIPE: MAXIMUM DEPTH (H) = 10'
VIRGINIA DEPARTMENT OF TRANSPORTATION

SPECIFICATION REFERENCE	233
	302

NOTES

- DEPTH OF INLET (H) TO BE SHOWN ON PLANS. MAXIMUM DEPTH (H) TO BE 20' FOR DEPTHS LESS THAN 10' USE STANDARD DI-1.
- THE 1/4" DIMENSION SHOWN ON THE STANDARDS IS TO BE MEASURED FROM THE INVERT OF THE OUTFALL PIPE TO THE TOP OF THE STRUCTURE. PLAN "H" DIMENSIONS ARE APPROXIMATE ONLY. FOR ESTIMATING PURPOSES AND THE ACTUAL DIMENSIONS SHALL BE DETERMINED BY THE CONTRACTOR FROM FIELD CONDITIONS.
- WHEN SPECIFIED ON THE PLANS THE INVERT IS TO BE SHAPED IN ACCORDANCE WITH STANDARD ST-1. THE COST OF FURNISHING AND PLACING ALL MATERIALS INCIDENTAL TO THE SHAPING IS TO BE INCLUDED IN THE BID PRICE FOR THE STRUCTURE.
- IN THE EVENT THE INVERT OF THE OUTFALL PIPE IS HIGHER THAN THE BOTTOM OF THE STRUCTURE, THE INVERT OF THE STRUCTURE SHALL BE SHAPED WITH CEMENT MORTAR TO PREVENT STANDING OR POOLING OF WATER IN THE STRUCTURE. THE COST OF FURNISHING AND PLACING ALL MATERIALS INCIDENTAL TO THE SHAPING IS TO BE INCLUDED IN THE BID PRICE FOR THE STRUCTURE.
- STEPS ARE REQUIRED. FOR DETAILS SEE STANDARD ST-1.
- THIS ITEM MAY BE PRECAST OR CAST-IN-PLACE.

REINFORCING STEEL SCHEDULE

MARK	SIZE	NO REQD	LENGTH
Bars H	#5	8x(H+2)	3'-10"
Bars V	#4	40	H+4"

APPROXIMATE QUANTITIES FOR MINIMUM (10') DEPTH

CONCRETE PIPE DIAMETER	CONCRETE Cu. Yds.	REINFORCING STEEL Lbs.
12"	5,218	655
15"	5,193	651
18"	5,163	647
24"	5,089	639

Increments to be added for each additional foot of depth (H):
0.465 Cu. Yds. of concrete
58.7 Lbs. of reinforcing steel

STANDARD DROP INLET
12" - 24" PIPE: DEPTH (H) 10' TO 20'
VIRGINIA DEPARTMENT OF TRANSPORTATION

SPECIFICATION REFERENCE	233
	302