



- NOTES:**
1. CONCRETE TO BE 4000 PSI MINIMUM COMPRESSIVE STRENGTH.
  2. FOR DETAILS OF HEADWALL BEVEL SEE STANDARD EW-2SPC, SHEET 101.10.
  3. REINFORCING STEEL IN ACCORDANCE WITH ASTM A-615 (REINFORCING BARS).
  4. PIPE OPENINGS IN PRECAST DRAINAGE UNITS SHALL NOT EXCEED 4 INCHES AT ANY GIVEN POINT BETWEEN THE PIPE AND THE PRECAST UNIT.
  5. DIMENSIONS SHOWN ARE MINIMUM. ACTUAL MEASUREMENTS MAY VARY WITH MANUFACTURER'S TOLERANCES.
  6. IN NO CASE SHALL TOP OF ENDWALL PROTRUDE ABOVE FILL SLOPE, DITCH SLOPE, OR SHOULDER.
  7. HEADWALL TO BE BEVELED IN ALL AREAS EXCEPT WHERE A CONFLICT WITH INVERT OR WINGWALL OCCUR.
  8. BEVEL EDGE AS REQUIRED ON THE HEADWALL AT THE INLET END OF THE CULVERT (WHERE THE FLOW ENTERS THE CULVERT).
  9. HEADWALL AT THE OUTLET END OF THE CULVERT MAY BE EITHER SQUARE EDGE OR BEVEL EDGE.
  10. 3/4" CHAMFER MAY BE PROVIDED ON ALL EDGES AT MANUFACTURER'S OPTION.

**FOR CIRCULAR CONCRETE OR CORRUGATED METAL PIPE**

| DIMENSIONS |           |         |         |                      |                    |                      |                    |           |           |
|------------|-----------|---------|---------|----------------------|--------------------|----------------------|--------------------|-----------|-----------|
| PIPE I.D.  | H         | T       | S       | L-30°<br>1/2:1 SLOPE | L-30°<br>2:1 SLOPE | L-45°<br>1/2:1 SLOPE | L-45°<br>2:1 SLOPE | a         | b         |
| 42"        | 5'-6"     | 16'-6"  | 6'-0"   | 6'-7 1/2"            | 8'-8"              | 8'-0"                | 10'-6"             | 0'-4 1/2" | 0'-3 1/2" |
| 48"        | 6'-0"     | 18'-4"  | 6'-10"  | 7'-6"                | 9'-9 3/4"          | 9'-2 1/2"            | 12'-0"             | 0'-5"     | 0'-4"     |
| 54"        | 6'-6"     | 20'-3"  | 7'-8"   | 8'-4 1/2"            | 10'-11 1/2"        | 10'-3"               | 13'-6"             | 0'-5 3/4" | 0'-4 1/2" |
| 60"        | 7'-0"     | 22'-2"  | 8'-6"   | 9'-3"                | 12'-1 1/4"         | 11'-3 1/2"           | 14'-10 1/4"        | 0'-6 1/4" | 0'-5"     |
| 66"        | 7'-7"     | 24'-0"  | 9'-4"   | 10'-1 1/4"           | 13'-3 1/2"         | 12'-4 1/2"           | 16'-4"             | 0'-7"     | 0'-5 1/2" |
| 72"        | 8'-2"     | 25'-11" | 10'-2"  | 11'-0"               | 14'-5 1/2"         | 13'-5 1/2"           | 17'-8"             | 0'-7"     | 0'-5 1/2" |
| 78"        | 8'-8 1/2" | 27'-10" | 11'-0"  | 11'-10"              | 15'-7"             | 14'-6"               | 19'-0"             | 0'-7"     | 0'-5 1/2" |
| 84"        | 9'-3"     | 29'-8"  | 11'-10" | 12'-8 1/2"           | 16'-9"             | 15'-6"               | 20'-6"             | 0'-7"     | 0'-5 1/2" |
| 90"        | 9'-11"    | 31'-8"  | 12'-8"  | 13'-7"               | 17'-11"            | 16'-7 1/2"           | 21'-11"            | 0'-7"     | 0'-5 1/2" |
| 96"        | 10'-7"    | 33'-8"  | 13'-6"  | 14'-5 1/4"           | 19'-1"             | 17'-8 1/4"           | 23'-4"             | 0'-7"     | 0'-5 1/2" |

SPECIFICATION REFERENCE

105  
302

**PRECAST ENDWALLS FOR MULTIPLE PIPE CULVERTS**  
42" - 96" CIRCULAR PIPES WITH 45° SKEW

VIRGINIA DEPARTMENT OF TRANSPORTATION



ROAD AND BRIDGE STANDARDS

REVISION DATE

SHEET 1 OF 1

101.21