



Notes:

No other conductors shall be run in the same conduit with electrical service cable.

For underground service installations, local power utility company will install service power utility cable from their power source to the junction box and make required splices to the service cable coiled in the junction box.

TYPE A

TYPE B

* JB-1A, 1B or 1C junction box
Top of junction box shall read "UTILITY"

**ELECTRICAL SERVICE DETAILS
SIGNAL INSTALLATION**

VIRGINIA DEPARTMENT OF TRANSPORTATION