

If the utility space is paved, construction shall be on compacted subgrade and the thickness shall match that of the sidewalk, however, the area will not be considered part of the minimum width required for sidewalk.

If trees are planted in paved pedestrian areas, they shall be planted in tree wells that include a planting grate, approved by the District Administrator's Designee. However, the width of sidewalk passing the tree well shall be at least 4 feet in width.

FIGURE 6 - DETAIL BACK OF CURBS

H. PRIVATE ENTRANCES

1. Curb and gutter private entrances

At all driveway entrances, standard entrance gutter (Std. CG-9B or CG-9D) shall be used with Standard CG-6 or CG-7 curb and gutter. A special design entrance gutter shall be submitted to the District *Engineer/Administrator's Designee for approval when roll top curb is used, similar to that shown in Figures 7 and 8.

٠

^{*} Rev. 7/15