



DETAILS OF LOAD CARRYING GRATE B

GRATE A BAR SPACING CHART		
GRATE	MAXIMUM DIMENSION	
TYPE	a	Ь
ΑI	11/2"	3"
ΑШ	1"	1"

NOTES:

- 1. SEE GENERAL NOTES-PRECAST FOR ADDITIONAL DETAILS.
- 2. CONCRETE COVER AND GRATE ARE TO BE FURNISHED AS A SINGLE UNIT. OUTSIDE DIMENSIONS OF GRATE ARE TO BE 3'-4" X 2'-11½" (GRATE A) OR 3'-4" X 2'-11½" (GRATE B).
- 3. DIMENSIONS SHOWN ARE MINIMUM. ACTUAL DIMENSIONS MAY VARY WITH MANUFACTURER.
- 4. GRATE A IS TO BE UTILIZED IN LOCATIONS NOT NORMALLY SUBJECT TO TRAFFIC.
- GRATE B IS TO BE UTILIZED IN LOCATIONS NORMALLY SUBJECT TO TRAFFIC.
- 6. ALTERNATE METHODS OF ANCHORING ANGLE IRON WILL BE ACCEPTABLE IF APPROVED BY THE ENGINEER.
- GRATE AND COLLAR ARE TO BE GALVANIZED AFTER FABRICATION.
- 8. JOINTS BETWEEN CONCRETE COVER AND GUTTERS (WHEN REQUIRED) ARE TO BE DOWELED, KEYED, OR OTHER VDOT APPROVED METHODS.
- 9. CONCRETE SHALL BE 4000 PSI MINIMUM.
- 10. REINFORCING STEEL SHALL BE IN ACCORDANCE WITH ASTM A-615.
- 11. GRATE BARS ARE TO BE INSTALLED SO THEY WILL BE ALIGNED PARALLEL TO THE DITCH FLOW.
- 12. SEE STANDARD DI-7, 7A, 7B FOR DETAILS OF GUTTER, METHOD OF PLACEMENT, ALTERNATE METHODS OF CONSTRUCTION.

SPECIFICATION REFERENCE	
105	

233

302

VIRGINIA DEPARTMENT OF TRANSPORTATION

STANDARD PRECAST TOP UNITS

VDOT

ROAD AND BRIDGE STANDARDS

REVISION DATE

SHEET 1 OF 1

103.08