



NOTES:

1. GRATE AND COLLAR ARE TO BE GALVANIZED AFTER FABRICATION. COST OF THIS GRATE AND COLLAR ARE TO BE INCLUDED IN THE PRICE BID FOR STORMWATER MANAGEMENT DRAINAGE STRUCTURE.
2. STRUCTURE MAY BE PRECAST OR CAST IN PLACE. SEE SHEET 2 OF 3 FOR DETAILS ON PRECAST STRUCTURE.
3. WEEP HOLES SHALL NOT BE PROVIDED.
4. STEPS ARE TO BE PROVIDED WHEN HEIGHT OF STRUCTURE IS 4'-0" OR GREATER ABOVE INVERT OF OUTLET PIPE. FOR STEP DETAILS SEE STANDARD ST-1.
5. FOR DETAILS ON METAL PLATE AND DEBRIS RACK SEE STANDARD SWM-DR.
6. MARK HEIGHT OF STRUCTURE, IN BLACK, WITH 4" HIGH NUMERALS AND 1" WIDE HORIZONTAL STRIPES AT 1' INTERVALS FROM INVERT OF WATER QUALITY ORIFICE (ALL VISIBLE SIDES).
7. STORMWATER MANAGEMENT DRAINAGE STRUCTURE, STANDARD SWM-1, MAY BE USED AS A TEMPORARY SEDIMENT BASIN DURING CONSTRUCTION. SEE STANDARD SWM-DR, SHEET 1 OF 3, FOR TEMPORARY SEDIMENT BASIN DETAILS.

SHEET 1 OF 3

SPECIFICATION REFERENCE

302

STORMWATER MANAGEMENT DRAINAGE STRUCTURE

VIRGINIA DEPARTMENT OF TRANSPORTATION

Filename: replace116
Directory: K:\Electronic Pubs\2001 Standards\Word\3-03rev
Template: C:\Program Files\Microsoft Office\Office\Normal.dot
Title:
Subject:
Author: kelley_pe
Keywords:
Comments:
Creation Date: 2/19/2003 3:20 PM
Change Number: 3
Last Saved On: 3/3/2003 11:04 AM
Last Saved By: kelley_pe
Total Editing Time: 2 Minutes
Last Printed On: 3/11/2003 2:28 PM
As of Last Complete Printing
Number of Pages: 6
Number of Words: 2 (approx.)
Number of Characters: 15 (approx.)