



**NOTES:**

1. SETTLEMENT PLATES SHALL BE PLACED AS SHOWN ON PLANS OR AS DIRECTED BY THE ENGINEER.
2. ALL WELDED CONNECTIONS BETWEEN BASE PLATE, RISER PIPE, AND FINS SHALL BE IN ACCORDANCE WITH SECTION 407 OF THE SPECIFICATIONS.
3. STEEL PLATE SHALL BE 1/2" THICK AND CONFORM TO ASTM A36.
4. RISER PIPE SHALL BE 1" SCHEDULE 40 (A-53) STEEL PIPE INSTALLED IN 4' SECTIONS AS REQUIRED.
5. CASING IS TO BE SCHEDULE 40 STEEL OR PVC INSTALLED IN 4' SECTIONS AS REQUIRED. THREADED FITTINGS ARE REQUIRED FOR STEEL PIPE, PVC FITTINGS SHALL BE GLUED WITH PVC PIPE CEMENT.
6. A PROTECTIVE CAP IS REQUIRED AT THE TOP OF THE CASING PIPE TO PREVENT DEBRIS FROM ENTERING THE CASING.
7. THE COUPLING MAY BE OMITTED AND THE RISER PIPE WELDED DIRECTLY TO THE BASE PLATE.

<p>SPECIFICATION REFERENCE</p> <p>303 407</p>	<p>A COPY OF THE ORIGINAL SEALED AND SIGNED DRAWING IS ON FILE IN THE CENTRAL OFFICE.</p> <h2 style="margin: 0;">SETTLEMENT PLATE</h2> <p>VIRGINIA DEPARTMENT OF TRANSPORTATION</p>	<p><b>VDOT</b></p> <p>ROAD AND BRIDGE STANDARDS</p> <p>REVISION DATE 04/19</p> <p>SHEET 1 OF 1</p> <p>601.07</p>
---	---	--