

If the utility space is paved, construction shall be on compacted subgrade and the thickness shall match that of the sidewalk, however, the area will not be considered part of the minimum width required for sidewalk.

If trees are planted in paved pedestrian areas, they shall be planted in tree wells that include a planting grate, approved by the District Administrator's Designee. However, the width of sidewalk passing the tree well shall be at least 4 feet in width.

FIGURE 6 - DETAIL BACK OF CURBS

## H. PRIVATE ENTRANCES

1. Curb and gutter private entrances

The Standard CG-9D entrance gutter is to be used for most single family residential entrances with curb and gutter.

The Standard CG-9A and 9B entrance gutters should be considered only as a last resort in situations where the access into the property is too narrow to accommodate a Standard CG-9D, or if it is known that the lane adjacent to the curb will be used as a parking lane **AT ALL TIMES**.\*

A special design entrance gutter shall be submitted to the District Engineer/Administrator's Designee for approval when roll top curb is used, similar to that shown in Figures 7 and 8.

<sup>\*</sup> Rev. 7/18