

SECTION 242—FENCES

242.01—Description

These specifications cover material requirements for fence components used in the construction of chain link, pedestrian, barbed wire, woven wire, and lawn fences and material specifications for temporary silt fences, geotextile fabric silt barriers, and filter barriers used for erosion control.

242.02—Detail Requirements

Steel posts and braces for standard fence and chain link fence may be fabricated from pregalvanized material in lieu of galvanization after fabrication provided ends and other areas of exposed metal are

(c) Temporary Silt Fences, Geotextile Fabric, Silt Barriers, and Filter Barriers:

- 1 **Geotextile fabric** shall conform to the requirements of Section 245.
- 2 **Posts for temporary silt fences** shall be a nominal 2 1/2 by 2 1/2 inch or 3 inch diameter No. 2 Southern pine, a nominal 2 by 2 inch oak, or steel having a weight of at least 1.25 pounds per linear foot and a length of at least 5 feet.
- 3 **Supports for temporary filter barriers** shall be a nominal 1 by 2 inch or 1 1/2 inch diameter No. 2 Southern Pine or oak or steel having a weight of at least 1.00 pound per linear foot and a length of at least 2.5 feet.