



Notes:

No other conductors shall be run in the same conduit with electrical service cable.
 For alternate method of service cable and ground wire entering breaker box, see standard SE-5.

TYPE A

**ELECTRICAL SERVICE DETAILS
 SIGNAL INSTALLATION**

VIRGINIA DEPARTMENT OF TRANSPORTATION